

# PHOTOLOG

ROLL  
#5

Frame	Date	Direction	Subject
11	8/26/00	NW	Preparatory work for JI-A transformer to be pumped. JI-A has >500 ppm PCB.
12	8/26/00	NW	JI-A Transformer being pumped. The oil <sup>is</sup> contains PCB >500 ppm and is being pumped into a Blue triad pump truck.
13	8/26/00	W	JI-B is hooked up and <del>has</del> <sup>is</sup> being pumped. JI-B is located approx. 5 feet from JI-A. JI-B also has >500 ppm PCB.
14	8/26/00		JI-D preparatory work. About to be pumped into a SAFE CLEAN truck. JI-D contains in between 500 > 50 PCB's.
15	8/26/00	NW	JI-C Transformer - about to be pumped empty of oil. Contains >500 PCB's.
16	8/26/00	W	Blue Triad Truck that is backed up inside JI building to empty contents of the JI-C transformer.
17	8/26/00	N	Yellow Safety Kleen truck parked in JI building to empty out the contents of the JI-D transformer.



ROLL  
#5

Frame	Date	Direction	Subject
18	8/26/00	NW	J1-C transformer is now being pumped into a Blue Triad Truck. J1-C contains over 500 ppm PCB
19	8/26/00	W	Truck, white enviro safe. Parked in between pump house & J1 building
20	8/26/00	NW	J1-E Transformer being pumped into a yellow safe kleen truck the J1-E contains between 50 & 500 ppm. PCB's.
21	8/26/00	NW	J1-C Transformer has been pumped and is now empty. J1-C <del>cont</del> <sup>RB</sup> contained >500 ppm PCB's. Contents were <del>emptied</del> <sup>pumped</sup> into a Blue Triad truck
22	8/26/00	NW	J-I transformer is being pumped into a <del>enviro</del> <sup>blue</sup> <del>safe</del> <sup>Triad</sup> truck. The J-I transformer contains >500 ppm. PCB's.
23	8/26/00	SW	J-H transformer contains between 50 & 500 PCB's, and is being pump into enviro serv. truck.

ROLL #6

Frame	Date	Direction	Subject
1	8/26	SW	J2-Q Transformer being pumped to empty the PCB's.
2	8/26	NE	J2-P transformer is being pumped to empty the PCB's. Located on
3	8/26	NE	J2-P transformer is finished pumping and is now banded up to prevent leaking.
4	8/26	SW	J2-Q transformer is finished pumping out all the PCB's. It is now empty.
5	8/26	N	<del>J2-N</del> Truck pumping PCB's out of J2-N Transformer.
6	8/26	NW	PH-M transformer is prepared to be pumped of its oil with PCB's.
7	8/28	E	Safety klean trucks that are pumping the oil contaminated w/ PCB's out of the SS-K and SS-J transformers. Both SS-K & SS-J contain between 50 & 500 <del>ppm</del> ppm PCB's

↓  
Continued

ROLL  
#6

Frame	Date	Direction	Subject
8	8/28	NW	SS-J transformer in preparatory work to be pumped empty of its oil containing 50-500 PCB's
9	8/28	NW	SS-K transformer in preparatory work to be emptied of its oil containing 50-500 PCB's
10	8/28	NW	SS-J transformer is now being pumped of its oil containing PCB's.
11	8/28	NW	SS-K transformer is now being pumped of its oil containing PCB's.

8/28 to 8/29 > Pictures continued of sampling on McIntyre and Cross Creek, and Stock Piles

ROLL  
#7

Frame	Date	Direction	Subject
1	8/30/00	NE	SS-L Transformer being prepared to be pumped of all its PCB oil. The PCB oil is <50ppm.
2	8/30/00	E	SS-L transformer is now being pumped of its PCB oil.
3	8/30/00	SE	HAZMAT truck that will pump the SS-L transformer which has lower than 50 ppm PCB's.
4	8/30/00	N	Staging area in the J1 building for all containers with possible chemicals to be placed on a poly sheet.
5	8/30/00	NW	J2-R transformer being prepared to be pumped empty of its oil's containing PCB's. This transformer contains <50ppm PCB's.
<del>5</del>	<del>8/30/00</del>	<del>SW</del>	<del>J2-R transformer is pumping all of its oil into a HAZMAT Tank</del>
6	8/30/00	NW	J2-R has been pumped empty of all its PCB oils

Frame	Date	Direction	Subject
7	8/30/00	W	J2-0 transformer is being prepared to be pumped of its PCB oil.
8	8/30	NW	J1-F transformer is being prepared to be pumped of its PCB oil.
9	8/30	W	J1-G transformer is being pumped of its PCB oil.